




Certificate 09/B072

**Barton Windows Ltd**  
**18 Brigg Road**  
**Barton-on-Humber**  
**North Lincolnshire**  
**DN18 5DH**

The above company's PVC-U windows have been assessed against the requirements of the British Fenestration Ratings Committee criteria for the energy rating of windows and achieved the following ratings:

Window system	Rating band	Rating value [kWhm <sup>-2</sup> (year) <sup>-1</sup> ]	$U_{\text{window}}$ (Wm <sup>-2</sup> K <sup>-1</sup> )	$g_{\text{window}}$	$L_{\text{factor}}$ (Wm <sup>-2</sup> K <sup>-1</sup> )
IB Sheerframe 7000 PVC-U Casement Diamant/Argon/Planitherm Total (Superspacer)	A	2	1.4	0.44	0.00
IB Sheerframe 7000 PVC-U Casement Planilux/Argon/Planitherm Total (Superspacer)	B	-5	1.4	0.41	0.00



Signed on behalf of the British Board of Agrément:

Date: 30th March 2009

This BFRC Certificate should not be confused with BBA Agrément Approval, details of which can be found on our website