

NBS Specification

System reference	AXTER LIGHTWEIGHT EXTENSIVE GREEN ROOF SYSTEM WITH ALPAFLORE
------------------	--

Q37 Green roofs

To be read with Preliminaries/General conditions

GENERAL HYDROLITE LIGHTWEIGHT EXTENSIVE GREEN ROOF SYSTEM

130A EXTENSIVE GREEN ROOF

To be read with Section J 41 ALPAFLORE for Green Roofs

- Roof type: Warm.
 - Substrate: As Section J 41.
 - Slope: As Section J 41.
- Waterproofing: ALPAFLORE as Section J 41 Clause 110 A.
- Thermal insulation: HYTHERM as Section J 41 Clause 110 A.
- Protection: None.
- Moisture control layer: HYDROLITE mineral substrate.
- Vegetation: Axter sedum blanket.
- Accessories: Axter edge retaining profile
20 to 40 rounded washed river gravel to all perimeters and major protrusions
Axter rainwater outlet inspection covers
Irrigations system (supplied and installed by others) in accordance with requirements.

140 PAVING AND DECKING SYSTEMS

- Type: As drawing ref. no. _____
- Paving support: Axter paving slab supports.

PERFORMANCE

210 GENERAL DESIGN

- Green roof and associated features: Complete the detailed design.
- Proposals: Submit drawings, technical information, calculations and manufacturers' literature.
- Performance criteria: as required.

PRODUCTS

340 MOISTURE RETENTION MAT to be installed under roof greening.

- Manufacturer: Axter Ltd.
 - Product reference: Axter mineral substrate.
- Material: Mineral fibre.
 - Capacity: 15 litres/m².

Axter - Green Roofs (Hydrolite Extensive)

This specification is for guidance only and Axter Ltd cannot be held responsible for any errors or omissions. It is the specifier's responsibility to ensure that the specification is suitable for the requirements of the construction.

NBS Specification

System reference	AXTER LIGHTWEIGHT EXTENSIVE GREEN ROOF SYSTEM WITH ALPAFLORE
------------------	--

400A VEGETATION BLANKET To green roof areas

- Manufacturer: Axter Ltd.
 - Product reference: Sedum blanket.
- Planting mix: As required.
 - Thickness: As manufactured.
- Vegetation coverage (minimum):80%.

420 EDGE RETAINING PROFILE To exposed edges of greening

- Manufacturer: Axter Ltd.
 - Product reference: Axter edge profile.
- Material: Aluminium.
- Height: As required.

430 INSPECTION CHAMBERS To all internal rainwater outlets

- Manufacturer: Axter Ltd.
 - Product reference: Axter inspection chamber.
- Material: Polyester powder coated steel.
- Size: 300 x 300 mm.
 - Depth: To suit planting.
- Access covers: integral into the unit.
- Features: perforated base.

460 SUPPORT PEDESTALS for paving slabs.

- Manufacturer: Axter Ltd.
 - Product reference: Axter adjustable paving slab supports.
- Type: Screw jack pedestal.
- Material: Recycled polypropylene.
- Dimensions: As required.
- Additional pedestals: Adjacent to perimeters.
- Accessories: Not required.

EXECUTION

710 INSTALLATION GENERALLY

- Preparation: Clear all surfaces of debris.
 - Timing: After certification of waterproof membrane integrity.
 - Surface condition: Visually inspect waterproof membrane, report any damage.
- Faults in waterproof membrane: Report.
- Contamination: Do not use materials detrimental to healthy plant growth.
- Storage: Do not overload.
 - Point loads: Avoid.
- Outlets: Do not block.
 - Outlet grilles: Installed.

720 ADVERSE WEATHER

- Unfinished work: Secure from damage and wind uplift.
- Conditions: Do not install or work with frozen materials.

Axter - Green Roofs (Hydrolite Extensive)

This specification is for guidance only and Axter Ltd cannot be held responsible for any errors or omissions. It is the specifier's responsibility to ensure that the specification is suitable for the requirements of the construction.

NBS Specification

System reference	AXTER LIGHTWEIGHT EXTENSIVE GREEN ROOF SYSTEM WITH ALPAFLORE
------------------	--

760 MOISTURE RETENTION MAT INSTALLATION

- Joints: Minimize.
 - Overlaps (minimum): Butt edges.
- Upstands: Fit closely around penetrations and outlets.

800 VEGETATION BLANKET INSTALLATION

- Handling blankets:
 - Timing: Lay within 36 hours of lifting from growing position.
 - Excessive stacking: Not permitted.
 - Material loss (maximum): 3% of total surface area.
- Growing medium condition: Thoroughly watered.
- Laying blankets:
 - Dry, damaged, frosty or waterlogged blankets: Do not lay.
 - Orientation: Diagonal or perpendicular to slope of roof.
 - Joints: Stagger. Butt together or slightly overlap to prevent gaps. Do not stretch blankets.
 - Edges: Finish with whole blankets.
 - Consolidation: Firm as laying proceeds to ensure full contact with the growing medium. Do not use rollers.
- Dressing: 2-5 mm horticultural grit.
 - Application: Brush in to fill joints.
- Watering: Thorough, immediately after laying and dressing.

820 EDGE RETAINING PROFILE INSTALLATION

- Cutting: Neat, accurate and without spalling.
 - Junctions: vertical, secured using proprietary connectors.
- Position: True to line and level. Smooth continuous lines.
- Fixing: Overlapped by roof coating.

830 INSPECTION CHAMBER INSTALLATION

- Location: Install centrally over drain outlet.
 - Orientation: Align parallel with adjacent features.
- Bedding: Proprietary support base.
- Backfill: Ballast.
- Surround: Growing medium.

840 PEDESTAL INSTALLATION

- Ensure that surface to accept pedestals is clean and free of debris.
- Setting out: Mark centre-point of pedestal on substrate surface, with perpendicular guidelines to ensure square layout.
 - Orientation: Align parallel with adjacent features.
 - Spacing: To suit paving material and dimensions.
- Overall movement tolerance (maximum): 3 mm.

Axter - Green Roofs (Hydrolite Extensive)

This specification is for guidance only and Axter Ltd cannot be held responsible for any errors or omissions. It is the specifier's responsibility to ensure that the specification is suitable for the requirements of the construction.

NBS Specification

System reference	AXTER LIGHTWEIGHT EXTENSIVE GREEN ROOF SYSTEM WITH ALPAFLORE
------------------	--

COMPLETION

910 INSPECTION

- Timing: Before handover.
 - Give notice (minimum): 3 days.

920 COMPLETION

- General: Leave the works in a clean, tidy condition.
- Surfaces: Clean immediately before handover.
- Outlets: Clean and clear of obstructions.
- Completed green roof: Protect from adjacent or high level working.

930 DOCUMENTATION

- Timing: Submit at handover.
- Contents:
 - Growing medium declaration of analysis.
 - Manufacturers' guarantees and warranties.
 - Procedures for maintenance of the green roof.
 - Record drawings showing the location of planting and associated features.
- Number of copies: as required.

Axter - Green Roofs (Hydrolite Extensive)

This specification is for guidance only and Axter Ltd cannot be held responsible for any errors or omissions. It is the specifier's responsibility to ensure that the specification is suitable for the requirements of the construction.